



જીલ્લા પ્રયોગશાળા
ગુજરાત પાણી પુરવઠા અને
ગટર વ્યવસ્થા બોર્ડ,
પ્રથમ માળ, જલભવન,
આર. ટી. ઓ. સામે, પાલાવાસાણા,
મેહસાણા-૩૮૪૦૦૩



District Laboratory
Gujarat Water Supply and
Sewerage Board
First Floor, Jalbhavan,
Opposite R.T.O., Palavasana,
Mehsana-384003



E-mail : dl.mahesana@gmail.com

Test Report

Name & Address of Customer:-

The Principal
Rangoli International School
Mehsana
Govt.
--

Customer Reference No.& Date:, 05/Aug/2026

Sample Submitted by : Sender

Date of Sample Receipt : 05-Aug-2026

Analysis Starting Date : 06-Aug-2026

Analysis Completion Date : 06-Aug-2026

ULR No.:NABLT0626GJ1827326000000603

Dicipline : Chemical Testing, Group : Drinking Water

Test Report No.: 1375 / 2026-2027.			Date of Issue : 07-Aug-2026	
Sample ID : MCW-1375 / 08-2026			Mode of Sample: Satisfactory	
Main Source : Surface water			Source : R.o Water	
Location : R.O Mineral Water				
Village : Nagalpur			Habitation : Nagalpur	
Taluka : Mehsana			District : Mehsana	
Latitude : 23.584903			Longitude : 72.377113	
Kindly find herewith the Analytical Results.			Sample Type: Drinking Water	
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (24th Ed.2023), Method: 2120 B	1.00
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Taste	-	IS : 3025 (Part 8) - 1984	Agreeable
4	Turbidity	NTU	APHA (24th Ed.2023), Method: 2130 B	< 1
5	pH at 25°C	-	APHA (24th Ed.2023), Method: 4500 H+ B	7.02
6	Conductivity at 25°C	µS/cm	APHA (24rd Ed.2023) Method: 2510 B	245
7	Total Dissolved Solids at 180 °C	mg/L	APHA (24th Ed.2023), Method: 2540 C	176
8	Total Hardness (as CaCO ₃)	mg/L	APHA (24th Ed.2023), Method: 2340 C	48
9	Calcium (as Ca ⁺²)	mg/L	APHA (24th Ed.2023), Method: 3500 Ca+2 B	11
10	Magnessium (as Mg ⁺²)	mg/L	APHA (24th Ed.2023), Method: 3500-Mg+2 B	5
11	Chloride (as Cl ⁻)	mg/L	APHA (24th Ed.2023), Method: 4500-Cl – B	17
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24th Ed.2023), Method: 4500-SO4-2 E	3
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24rd Ed.2023) Method: 4500-NO3- B	2.00
14	Fluoride (as F ⁻)	mg/L	APHA (24th Ed.2023), Method: 4500-F – C	0.09
15	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24th Ed.2023), Method: 2320 B	72

This Report is issued under the following terms & Condition :


1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time 7 Days otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Sample is collected by sender.

Checked By :


Urja Patel
Senior Chemist
Technical Manager
District Laboratory
GWSSB, Mehsana



Issued By:


Priya Raval
Authorized Signatory
Quality Manager
District Laboratory
GWSSB, Mehsana

End of the Test Report

O.W.No. DLMSN / CTR / 460 / of 2026, Dt. 7 / 8 / 2026

1st Floor, "Jalbhavan", Opp. RTO, Palavasana, Mehsana-384003



URBAN HEALTH CENTER-3 - NAGALPUR
OPP.EVM Storage Center, Near Swastik Homes Society,
Nagarpur MEHSANA
E-MAIL ID : uhc3nagarpurmmc@gmail.com

Dated: 25/08/2026

It is certified that an inspection team headed by Dr. Harshida Gavit Urban health officer from Urban health center -3, Nagarpur inspected the Rangoli International School, situated on Ramba Campus, opp. Nagarpur college, Mehsana on 25/08/2026 and found that the facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt.

The above is valid a period of TWO yr.


Urban Health Officer
Urban Health Center-3
Signature with Seal :MEHSANA.....
Name : Dr. Harshida S. Gavit
Designation : Urban Health Officer
Name & Address of the Office/ Department: UHC-3 Nagarpur

To

Rangoli International School,
Ramba Campus, Nagarpur,
Mehsana-384002